



Ministry of
the Environment

Well T₂

A107145

(flow)

Well Record

Regulation 903 Ontario Water Resources Act

Well Location

Address of Well Location (Street Number/Name) 116 Glenwood PLACE		Township Glenelg	Lot 99	Concession 26RW
County/District/Municipality West Grey		City/Town/Village	Province Ontario	Postal Code N6G1H0
UTM Coordinates NAD 83	Zone 18	Easting 500000	Northing 5000000	Municipal Plan and Sublot Number Other

Overburden and Bedrock Materials/Abandonment Sealing Record (see instructions on the back of this form)

General Colour	Most Common Material	Other Materials	General Description	Depth (m/ft) From	To
Brown	FILL CLAY & STONES Limestone		MED-HARD	0	4 FT
				4	50 FT
				50	130 FT

Annular Space		
Depth Set at (m/ft) From	To	Type of Sealant Used (Material and Type)
0	20 FT	50 gal GROUT Slurry 150 LBS 7/8 Hole Plug

Method of Construction		Well Use	
☐ Cable Tool	☐ Diamond	☐ Public	☐ Commercial
☒ Rotary (Conventional)	☐ Jetting	☒ Domestic	☐ Municipal
☐ Rotary (Reverse)	☐ Driving	☐ Livestock	☐ Test Hole
☐ Boring	☐ Digging	☐ Irrigation	☐ Cooling & Air Conditioning
☐ Air percussion		☐ Industrial	
☐ Other, specify		☐ Other, specify	

Construction Record - Casing			Status of Well	
Inside Diameter (cm/in)	Open Hole OR Material (Galvanized, Fibreglass, Concrete, Plastic, Steel)	Wall Thickness (cm/in)	Depth (m/ft) From	To
6 inch	STEEL	1.88	0	52 FT

Construction Record - Screen			Status of Well	
Outside Diameter (cm/in)	Material (Plastic, Galvanized, Steel)	Slot No.	Depth (m/ft) From	To

Water Details		Hole Diameter	
Water found at Depth	Kind of Water: ☒ Fresh ☐ Untested	Depth (m/ft)	Diameter (cm/in)
130 (m/ft) ☐ Gas	☐ Other, specify _____	From	To
Water found at Depth	Kind of Water: ☐ Fresh ☐ Untested	0	20FT
(m/ft) ☐ Gas	☐ Other, specify _____	20	52FT
Water found at Depth	Kind of Water: ☐ Fresh ☐ Untested	52	130FT
(m/ft) ☐ Gas	☐ Other, specify _____		

Business Name of Well Contractor KAUFMAN INVESTMENTS LTD.		Well Contractor's Licence No. 6634
Business Address (Street Number/Name) 314023 HWY #6 RR#1 DURHAM		Municipality WEST GREY
Province ONTARIO	Postal Code N6G1H0	Business E-mail Address
Bus. Telephone No. (inc. area code) 519 369 3394		Name of Well Technician (Last Name, First Name) KAUFMAN PAUL
Well Technician's Licence No. 19222		Date Submitted 2012 02 29

Results of Well Yield Testing			
After test of well yield, water was: ☐ Clear and sand free ☒ Other, specify Cloudy		Draw Down	
If pumping discontinued, give reason:		Time (min)	Water Level (m/ft)
Pump intake set at (m/ft) AIR 130'		Static Level	62 FT
Pumping rate (l/min / GPM) 76 GPM		1	69
Duration of pumping 2 hrs + 30 min		2	76
Final water level end of pumping (m/ft) 78 FT		3	78 FT
If flowing give rate (l/min / GPM)		4	78 FT
Recommended pump depth (m/ft) 110 FT		5	
Recommended pump rate (l/min / GPM) 76 GPM		10	
Well production (l/min / GPM) 76 GPM		15	
Disinfected? ☒ Yes ☐ No		20	
		25	
		30	
		40	
		50	
		60	

Map of Well Location	
Please provide a map below following instructions on the back.	
Comments: DURHAM	
Well owner's information package delivered ☐ Yes ☐ No	Date Package Delivered 2011 10 10 Date Work Completed 2011 10 10
Ministry Use Only Audit No. 2121563 MAR 07 2012 Received	